

[Conventional Fire Systems](#)[Sounders & VADs](#)[Symphoni LX Wall Sounder VAD](#)[◀ Back to Search results for "BF433C/F/7" \(2 other results\)](#)

Symphoni LX Wall Sounder VAD

Part No. **BF433C/F/7**

- Certified to EN54 Parts 3 and 23 (AFNOR/VDS) and 13 (BSI).
- Provides W-2.4-7.5 coverage (switchable to W-2.4-2.5 if required).
- 100dB(A) sound output.
- 15-30mA alarm current depending on setting.
- Attractive slim design.
- Ideal for use in bedrooms, bathrooms and toilets.



Technical Specifications



Approvals/certifications	Certified to EN54-3 and EN54-23 by AFNOR/VDS and EN54-13 by the BSI.
Protocol/compatibility	Can be used on the conventional sounder circuits of most conventional fire panels including C-TEC's FP, MFP, CFP & EP203. Can also be used on the conventional sounder circuits provided on CTEC's XFP and ZFP addressable panels.
Application/operation	Designed to be wall mounted. Suitable for indoor areas only.
VAD category & coverage	W-2.4-7.5 (switchable to W-2.4-2.5, reducing power consumption by up to 50%).
Flash rate & colour	1Hz (switchable) / red.
Supply/operating voltage	18-28V DC.
Quiescent current	TBC.
Nominal SPL (Sound Pressure Level)	100dB(A) when set to tone 29.
Alarm current	15-30mA dependent on setting.
Product dimensions (mm)	111mm diameter x 100mm deep.
Construction & finish	ABS FR & polycarbonate.
IP Rating	IP66
Weight	200g.
Operating conditions/temperature	-25°C to +70°C.

Approval Certificates



EN54-13 System Approval Certificate (BSI)

 Download

7 other products in the same category:



Solista LX Wall VAD



Solista LX Ceiling VAD



RoLPLX Wall Sounder VAD



Askari Bedhead Sounder



ROLP Wall Sounder



Symphoni LX Wall Sounder



Verso Base Sounder

CONTACT US

 C-TEC , Challenge Way, Wigan, WN5 0LD, UK Opening times: 08:30 - 17:00 GMT.

 **+44 (0) 1942 322744**

 sales@c-tec.co.uk
