

## **GRIDPRO Interchangeable Plates**

<b>Product Range</b>
----------------------

<b>GRIDPRO Interchangeable Plates</b>	
CL20506	6 Gang Metal Clad Grid Plate
CL20506B	6 Gang Metal Clad Grid Plate (No Knockouts In Back Box)
CL20508	8 Gang Metal Clad Grid Plate
CL20508B	8 Gang Metal Clad Grid Plate (No Knockouts In Back Box)
GR20400	3 - 4 Module Yoke
WA512	2 Gang Double Row K/O Box 47mm Deep



CL20506, CL20506B



CL20508, CL20508B



GR20400





WA512 (Optional)

V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB


Errors & Omissions excluded. Specification is subject to change without notice. GR20400 to be used with all plate sizes. Provided with 40mm deep back boxes

**Telephone:** 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com Facsimile: 01827 63362 Website: www.scolmore.com



### **GRIDPRO Interchangeable Plates**

### Product Dimensional Drawings (mm)



146

0

o

o


207

CL20509

o


o

o




CL20512


4.5



WA512 47 137 38.35 60.3 137 38.35 120.6



GR20400



Errors & Omissions excluded. Specification is subject to change without notice.

V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 E-mail: sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362 Website: www.scolmore.com



### **GRIDPRO Interchangeable Plates**

Technical Specification	
<b>GRIDPRO Interchangeable Plates</b>	
Material Composition	Front Plate & Back Box: Electrophoretically Coated Steel
	GR20400 & GR20600 Mounting Yoke: Galvanised Steel
	Earth Terminal: Brass, Earth Strap: Mild Steel
	Back Boxes: Electrophoretically Coated Steel
Cable Size	Dependent on modules fitted
Back Box Depth	40mm Provided / 56mm Provided (CL20518 & CL20524)
Knockout Sizes	5 x 20mm (1 Gang), 7 x 20mm (2 Gang)
	4 x 20mm, 4 x 25mm (CL20506 & CL20508)
	5 x 20mm, 5 x 25mm (CL20509 & CL20512)
	3 x 20mm, 9 x 25mm (CL20518)
	6 x 20mm, 6 x 25mm (CL20524)
Modular	Yes
Warranty	10 Years
IP Rating	IP20
<b>Operational Temperature</b>	-5° to +40°C
Standards	BS 5733 : 2010 + A1 : 2014, BS 4662: 2006 + A1: 2009

#### **Additional Information**

Ensure that the mains supply is isolated before commencing installation and refer to the circuit diagram with the relevant product.

Bare earth cables must always be covered with appropriate sleeving and wired to the earth terminal. CL20506 & CL20508 requires (2x) GR20400 3-4 Module Mounting Yokes. These plates are designed to be used with specified back box WA512 when flush mounting is required. 40mm back box supplied.

CL20509 & CL20512 requires (3x) GR20400 3-4 Module Mounting Yokes. These plates are designed to be used with specified back box WA518 when flush mounting is required. 40mm back box supplied.

CL20518 requires (3x) GR20600 6 Module Mounting Yokes. These plates are designed to be used with specified back box WA20518 when flush mounting is required. 56mm back box supplied.

CL20524 requires (4x) GR20600 6 Module Mounting Yokes. These plates are designed to be used with specified back box WA20524 when flush mounting is required. 56mm back box supplied.

Interchangeable with modules in the GRIDPRO system.

rrors & Omissions excluded. Specification is subject to change without notice.

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

**Telephone:** 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com Facsimile: 01827 63362 Website: www.scolmore.com





#### **Scolmore International Ltd**

1 Scolmore Park: Landsberg Lichfield Road Industrial Estate Tamworth, Staffordshire B79 7XB

- t: 01827 63454 f: 01827 63362 e: sales@scolmore.com
- w: www.scolmore.com

### **EU DECLARATION OF CONFORMITY**

- 1. Issuer Name Scolmore International Limited
- 2. Issuer Address

Iress 1 Scolmore Park, Landsberg, Lichfield Road Industrial Estate, Tamworth, Staffordshire, B79 7XB

- 3. Object(s) of Declaration
  a. Group
  b. Models No.
  CL20401, CL20401B, CL20402B, CL20403, CL20403B, CL20403B, CL20404 CL20404B, CL20506 CL20506B, CL20508B, CL20508B, CL20509B, CL20512B, CL20512B, CL20518B, CL20524, CL20524B
- 4. The object of the declaration described above is in conformity with the requirements of the following Legislations:
- 5. All products contained within the aforementioned comply with the relevant standards and requirements listed below.

BS 5733 : 2010 + A1 : 2014

6. I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable Essential Requirements of the Directives.

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001:2008.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of: Scolmore International Limited

# Dumer

Ross Turner - Technical Support Engineer



