

New Media Telephone Modules



New Media Telephone Modules



The New Media Modules offer a flexible build solution to a host of individual power socket outlet requirements. The clip fit grid modules are simple to install in their blank mounting plates.

New Media Telephone Modules

Product Range

New Media Telephone Modules

MM460**	Telephone Master Module
MM465**	Telephone Secondary Module
MM470**	RJ11 Outlet Module



MM460WH




MM465BK



MM470BK

Product Dimensional Drawings (mm)




Errors & Omissions excluded. Specification is subject to change without notice. ** Denotes Module Colour


New Media Telephone Modules

Wiring Diagrams


MM460



MM465



MM470



New Media Telephone Modules

Technical Specification

New Media Telephone Modules

Material Composition	Module: Polycarbonate
Connection Type	RJ11 Outlet - Screw Terminals Telephone Modules - IDC
Back Box Depth	25mm - 47mm (Dependant on Mounting Plate Used)
Module Size	Single Width (25mm x 50mm)
Modular	Yes
Warranty	1 Year
IP Rating	IP20
Operational Temperature	-5° to +40°C
Standards	BS 6312-2-2:1997 (where applicable) BS EN 50173-1:2011 (where applicable) BS 5733:1995 (where applicable)

Additional Information

Standard Euro Module Size.

Ensure that the mains supply is isolated before commencing installation and refer to the circuit diagram with the relevant product.

Bare earth cables must always be covered with appropriate sleeving and wired to the earth terminal.



DECLARATION OF CONFORMITY

1. *Issuer Name* Scolmore International Limited
2. *Issuer Address* 1 Scolmore Park, Landsberg,
Lichfield Road Industrial Estate,
Tamworth, Staffordshire, B79 7XB
3. *Object(s) of Declaration* New Media Range
 - a. *Group* Telephone Modules
 - b. *Model No.* MM460, MM465, MM470
4. *The object of the declaration described above is in conformity with the requirements of the following Legislations:*
5. *All products contained within the aforementioned comply with the relevant standards and requirements listed below.*

BS 6312-2-2 : 1997 (where applicable)

BS EN 50173-1 : 2011 (where applicable)

BS 5733 : 1995 (where applicable)

6. *I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable Essential Requirements of the Directives.*

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001:2008

Signed, for and on behalf of: Scolmore International Limited

Steven Bettson BSc - Senior Technical Support Engineer

CE 15