

## Installation Sheet

Please read these instructions carefully before commencing any installation.  
Retain for future reference.

CE IP20

### Important Information

It is recommended that installations are carried out by a qualified electrician who should ensure that the installation complies with current building regulations and BS7671.

Any damaged parts should be replaced immediately.  
JCC will not accept responsibility for any claims arising from a sub-standard installation.

### Important User Advice

Always isolate the mains supply before installing or servicing the equipment. It is essential that the installation does not infringe on water pipes or any other electrical services.

This system accessory is only suitable for indoor applications and must never be fitted to damp surfaces such as newly plastered or freshly painted ceilings.

### Installation.

This product is designed to be used with the JCC Mainline Track System.

It is recommended that thought be given to weight loading of the intended system layout. It is advisable to restrict the maximum distance between support cables to 1.5m. Care must be taken to ensure that all connecting track joints are secure and that if the track has been cut this has been done squarely and cleanly.

**Note:** Avoid mounting the suspended tracks in areas of strong air flow or near to ventilation systems.

# JC14094 2m Wire Suspension Kit

Finishes Available: White or Black


Accessories




Mainline Track System

#### Breakdown of Parts

Anchorage Plate x1 + Mounting Screws x2



Adjustable Wire Locator  
1 of 2



Ceiling Cover  
x1

2m Suspension Wire  
x1



+ Cable Clip  
x8




Track Locator Cover  
x1



Adjustable Wire Locator  
2 of 2




Track Locator Clip  
x1



Fully Assembled  
Suspension Kit


Track Section Profile



Timber Joist  
Ceiling

Assembly of Parts

Track Location  
Detail



JCC Lighting Aftersales:  
Technical Support Helpline: 01243 838986  
Customer Service Department: 01243 838999



BS EN ISO9001 - 2000  
Registered Firm  
Certificate No. GB 1552



jcc.co.uk