


Item Image



Wiring



Each coaxial cable should be connected to the appropriate terminal as shown.

This diagram applies to all unscreened non-isolated and isolated connections including diplex (TV/FM) units.

Care should be taken to ensure that the screening braid is clamped securely by the cable clamp and does not come into contact with the centre conductor.

## 73 TV W

Hartland Bright Steel 1 gang Non Isolated Television 1in/1out. Standard Insert will be White.

Primary Range	Hartland
Insert Type	TV & Satellite Outlets - Non Isolated
Plate Finish	Bright Steel
Frame Finish	
Switch Colour	
Body & Switch Trim	White
Height	Single = 88mm
Width	Single = 88mm
Depth	Single = 5mm
Fixing Hole Centres	Box Fixing = 60.3mmBox Fixing = 60.3mm
Minimum Wall Box Depth	25mm
Wattage	
Switched Poles	n/a
Current Rating	
Voltage	
Max load	
Contact Gap Minimum	n/a
Terminal Capacity 1	
Terminal Capacity 2	
Terminal Capacity 3	
Terminal Capacity 4	
Terminal Capacity 5	
Earth Terminal Capacity 1	5 x 1mm <sup>2</sup>
Earth Terminal Capacity 2	4 x 1.5mm <sup>2</sup>
Earth Terminal Capacity 3	3 x 2.5mm <sup>2</sup>
Earth Terminal Capacity 4	1 x 4mm <sup>2</sup> Multi-Strand
Earth Terminal Capacity 5	1 x 6mm <sup>2</sup>
Product Class 1	Must be earthed (ref BS7671 415.2.1)
Ambient Operating Temperature	-5° to +40° C
Recommended Location	Indoor use only
Standard/Approval	
Patents and Trademarks	Trade Mark No. 2344778

All products listed conform to current British or European standards and the product information is correct at the time of going to press.

All accessories are manufactured under an accredited BS EN ISO 9001 : 2008 Quality System.

It is the policy of the company to continually improve products as part of our development programme. Therefore, we reserve the right to alter designs and dimensions without prior notice.

Illustrations and diagrams are reproduced within the limitations of reproductions and printing processes are not binding.

Due to manufacturing processes we cannot guarantee an exact colour match and shadings of certain finishes.

Correct as at August 2012  
E&OE

R Hamilton & Co Ltd • Quarry Industrial Estate • Mere • Wiltshire • BA12 6LA • UK  
T: +44 (0)1747 860088 • F: +44 (0)1747 861032 • E: info@hamilton-litestat.com  
www.hamilton-litestat.com

Directors: R Hamilton • I Hamilton • RL Haines • CP Savory • AMH Hamilton (Secretary)  
Registered Office: Cedar House • Breckland • Linford Wood • Milton Keynes • MK14 6EX • Buckinghamshire  
Registered in London No. 941624 • VAT Registration No. 222 6607 84



BS EN ISO 9001:2008  
CERT. No. FM11238

