

## www.hamilton-litestat.com

## Wiring Each coaxial cable should be connected to the appropriate terminal as shown. This diagram applies to all unscreened non-isolated and isolated connections including diplex (TV/FM) units. Care should be taken to ensure that the screening braid is clamped securely by the cable clamp and does not come into contact with the centre conductor.

## **74 TV B**

Hartland Satin Steel 1 gang Non Isolated Television 1in/1out. Standard Insert will be Black.

Primary Range	Hartland	
Insert Type	TV & Satellite Outlets - Non Isolated	
Plate Finish	Satin Steel	
Frame Finish	Sacini Secot	
Switch Colour		
Body & Switch Trim	Black	
Height	Single = 88mm	
Width	Single = 88mm	
Depth	Single = 5mm	
Fixing Hole Centres	Box Fixing = 60.3mmBox Fixing = 60.3mm	
Minimum Wall Box Depth	25mm	
Wattage		
Switched Poles	n/a	
Current Rating		
Voltage		
Max load		
Contact Gap Minimum	n/a	
Terminal Capacity 1		
Terminal Capacity 2		
Terminal Capacity 3		
Terminal Capacity 4		
Terminal Capacity 5		
Earth Terminal Capacity 1	5 x 1mm2	
Earth Terminal Capacity 2	4 x 1.5mm2	
Earth Terminal Capacity 3	3 x 2.5mm2	
Earth Terminal Capacity 4	1 x 4mm2 Multi-Strand	
Earth Terminal Capacity 5	1 x 6mm2	
Product Class 1	Must be earthed (ref BS7671 415.2.1)	
Ambient Operating	-5° to +40°C	
Temperature		
Recommended Location	Indoor use only	
Standard/Approval		
Patents and Trademarks	Trade Mark No. 2344778	

All products listed conform to current British or European standards and the product information is correct at the time of going to press.	All accessories are manufactured under an accredited BS EN ISO 9001 : 2008 Quality System.	It is the policy of the company to continually improve products as part of our development programme.  Therefore, we reserve the right to alter designs and dimensions without prior notice.
Illustrations and diagrams are reproduced within the limitations of reproductions and printing processes are not binding.	Due to manufacturing processes we cannot guarantee an exact colour match and shadings of certain finishes.	Correct as at August 2012 E&OE

R Hamilton & Co Ltd • Quarry Industrial Estate • Mere • Wiltshire • BA12 6LA • UK T: +44 (0)1747 860088 • F: +44 (0)1747 861032 • E: info@hamilton-litestat.com www.hamilton-litestat.com

Directors: R Hamilton • I Hamilton • RL Haines • CP Savory • AMH Hamilton (Secretary) Registered Office: Cedar House • Breckland • Linford Wood • Milton Keynes • MK14 6EX • Buckinghamshire Registered in London No. 941624 • VAT Registration No. 222 6607 84







